



NOTES:

1. LSP (Line Surge Protection) device earths to either screw terminal or DIN Rail
2. Ensure local Earth stake is fitted as per TD-LSP-01 (to be wired to electrical authority regulations)

REVISIONS			
REV	DESCRIPTION	DATE	BY
1.0	Initial	03/10/2022	MD
1.1	Revision 1	03/11/2022	MD