

 <p><b>AQUAMONIX</b> Measure. Monitor. Master.</p> <p><b>Head Office:</b> 268 Milperra Road MILPERRA NSW 2214 ABN: 26 609 047 878 Ph: 1300 797 246 Web: <a href="http://www.aquamonix.com.au">www.aquamonix.com.au</a></p>	<p><i>Technical Bulletin Series</i> <b>Magnetic Flow Meters</b></p>	<p><b>TBWFP 065</b></p> <p>ISSUE: V1 DATE: Oct 2018 ECRO: N/A PAGES: 1</p>
---	---	--

## Aquamonix Emflux Flow Meter Pipe-Not-Full Cable Update

### APPLICABLE PRODUCTS

This technical bulletin applies to all Aquamonix Emflux Electromagnetic flow meter products.

### INFORMATION

Aquamonix have updated the colour of the Pipe-Not-Full cable to differentiate it from the main signal cable.

The cable specifications have not changed – all electrical properties, conductor sizes and materials have been preserved and are still identical between the black sheathed cable and the purple cable. The change is purely visual to distinguish the purposes of each cable.

The internal core colors of both black and purple cables will be identical – green, blue, red, yellow.



### TIMING

The change will take effect from December 2018 onwards for new production and field service.

### TRANSMITTER COMPATIBILITY

The cables will make no difference to the operation of the meter or its compatibility with older transmitters as construction of the new cable is identical to the existing black cable.